

जा.क्र. / प्राआकें / आस्था / 56 / 2024
प्राथमिक आरोग्य केंद्र, म्हासवड
दि. 26/06/2024

APPENDIX XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by **Medical Officer Primary Health Center Mhaswad.**
(Name of Officers with designation) from **MO (Medical Officer) PHED** (Name of Department/ Office)
Inspected the **Mary Matha High School & Jr. College, Mhaswad , Taluka- Man, District- Satara**
(Name & Address of the school) on **16/12/2023** (Date of inspection) and found that the
Mary Matha High School & Jr. College (Name of school) has safe drinking water facilities for the
students and members of staff of the institution and is maintaining the hygienic sanitation condition in
the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of One Year

To,

Mary Matha High School & Jr. College,
Mhaswad, Taluka- Man District- Satara
(Name & Address of the Institution)

Signature with Seal:.....

Name **Dr. Joach Kulkarni**.....

Designation :..... **MO**.....

Name & Address of the Office/Department

.....

Medical Officer
Primary Health Center
Mhaswad Tal. Man, Dist. Satara

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



॥ श्री ॥

ग्लोबल अग्रो सर्विसेस्

माती, पाणी, पान, देठ तपासणी प्रयोगशाळा.

e-mail : globel4stl@gmail.com

गट नं. ८/४, प्लॉट क्र. ५, हनुमाननगर माळेवाडी-अकलूज.
ता. माळशिरस, जि. सोलापूर मो.नं. : ९६८९०६९७७७

जावक क्र. : 011/2024-25.

दिनांक : / / २०१

Dt.24/05/2024


CERTIFICATE OF WATER ANALYSIS

REPORT NO :- GWD 011
FARMER NAME :- M/s. Mary Matha High School & Jr. College
VILLAGE NAME :- A/p. Mhasawad Tal. Mhasawad Dist.- Satara
GAT NO :-
CROP NAME :-
REF :- Drinking Water

Sr.No.	Parameters	Results	Drinking Limits	ISI Method
1.	Bacterial Plate count	10	Max.20 cfu/ml	1622
2.	E.coli	Absent	Absent/100 ml	1622
3.	Staphylococcus Aureus	Absent	Absent/100 ml	1622
4.	Appearance	Clear	Clear	-
5.	Smell	Agreeable	Agreeable	3025-05
6.	pH	7.5	6.5-8.5	3025-11
7.	Total Dissolved Solids	120	Max.500 mg/l	3025-16
8.	Hardness as CaCO ₃	100	Max.200 mg/l	3025-21
9.	Calcium as Ca	20	Max.75 mg/l	3025-40
10.	Magnesium as Mg	12	Max.30 mg/l	3025-46
11.	Alkalinity as CaCO ₃	70	Max.200 mg/l	3025-23
12.	Chlorides as Cl	65	Max.250 mg/l	3025-32
13.	Sulphates as SO ₄	60	Max.200 mg/l	3025-24

NPN TEST NEGATIVE

Remark :- This Water is Suitable for Drinking


LAB INCHARGE

